



# Langley Research Center Safety Alert

SA-01-94


Date: January 26, 1994

TO: DISTRIBUTION  
FROM: 429/Safety Manager, Head, Risk Management Branch, SE&MA  
SUBJECT: Air-Conditioner Units

On December 30, 1993, LaRC experienced a fire in the Environmentally Controlled Warehouse, Building 1249. The cause of the fire has been traced back to a window type air-conditioner with electric heat. The air-conditioner units in question were manufactured by Cold Point, provide 16,000 to 20,000 BTU cooling with/electric heat and have dimensions of 27" x 26 1/4" x 18".

Due to the potential for another mishap, it is imperative that all of these units be removed from service immediately. Please inventory your facility and note the locations of these units on the form below and return the form to the Risk Management Branch, M/S 429 by February 4, 1994.

Thank you for your prompt attention to this matter.

  
V. William Wessel  
4SAFE

Distribution:  
Facility Safety Heads  
Facility Coordinators

421/JVC

421/HTG

-----  
FACILITY

ROOM NUMBER

SERIAL NUMBER

-----

-----

-----

-----

-----

-----

-----

-----

-----